

PERFORMANCE RESULTS

Test performed according to BS 8525-2:2011

Manufacturer
INTEWA GmbH, Jülicher Straße 336, 52070 Aachen/Germany

AQUALOOP-System 6
Membrane Bioreactor with UV Disinfection
for the Treatment of Greywater

Class of greywater input	Bathroom greywater including washing machine effluent
Class of treated water output	Spray application
Nominal hydraulic daily load	200 l/d
Acceptance flow rate	1l/sec
Acceptance volume	100 l
Maximum storage time	21 days
Details of disinfection process	UV disinfection after storage
Nominal occupancy	4 beds
Power supply requirements	230 volts, 1 amps, Single phase

Performance tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH
(PIA GmbH)
Hergenrather Weg 30
52074 Aachen, Germany

Certified according to
ISO 9001:2008



Notified Body No.: 1739



Dr. rer. nat. Martina Defrain

April 2014

